

PJW Meters Unit 1 Salisbury House Salisbury Road, Newton Abbot Devon. TQ12 2DF Customer Service: 01626 368 595 www.pjwmeters.com

Data Sheet

2018 v1.0

DR2100-2MOD DIN Rail kWh Power Meter

• MID B&D Approved

- Class B (kWh) EC Directive 2004/22/EC
- 1000IMP/kWh Pulsed Output
- 2 Module Dinrail Mounted (35mm)
- Digital Backlit Display



DR2100-2MOD Single Phase Power Meter


The DR2100-2MOD Digital Power Meter works directly connected to a maximum load 100A AC circuit.

This meter has been MID B&D Certified, proving both it's accuracy and quality. This certification allows this model to be used for any sub-billing applications.

Unlike other alternatives, this meter is housed in a 2 Module DIN rail case, meaning it takes up very little space.

The DR2100-2MOD displays Total Active Energy and features a Pulsed Output to work in conjunction with many dataloggers.

Dimensions



Safety Instructions

The following safety instructions apply to all versions of the SDM230 range of power meters:

Information for your own safety

This manual does not contain all of the safety measures for operation of the equipment (module, device) because special operating conditions, and local code requirements or regulations may necessitate further measures. However, it does contain information which must be read for your personal safety and to avoid material damages. This information is highlighted by a warning triangle and is represented as follows, depending on the degree of potential danger.

Qualified personnel

Operation of the equipment described in this manual may only be performed by qualified personnel. Qualified personnel means a person who has been authorised to commission, start up, ground and label devices, systems and circuits according to Safety and Regulatory standards

Use for the intended purpose The equipment must only be used for the application specified in the datasheet and the user manual.

Proper handling The prerequisites for areliable operation of the product are proper transport, storage, installation and assembly, as well as proper operation and maintenance. When operating electrical equipment, certain parts of the equipment automatically carry dangerous voltages. Improper handling can therefore result in serious injuries or material damage. Use only insulating tools. Do not connect while circuit is live (hot). Place the meter only in dry surroundings. Do not mount the meter in an explosive area or expose the meter to dust, mildew and insects. Make sure the used wires are suitable for the maximum current of this meter. Make sure the AC wires are connected correctly before activating the current/voltage to the meter. Do not connect the meter to a 3 phase - 400VAC - network. Do not touch the meter connecting clamps directly with your bare hands, with metal, blank wire or other material as you may get an electrical shock. Make sure the protection cover is placed after installation. Installation, maintenance and reparation should only be done by qualified personnel. Never break the seals and open the front cover as this might influence the functionality of the meter, and will avoid any warranty. Do not drop, or allow physical impact to the meter as there are high precision components inside that may break

DR2100-2MOD Digital Power Meter - Single Phase

Measured Parameters

The DR2100-2MOD monitors and displays Total Active Energy (kWh) of a single phase two wire (1p2w) system.

Technical Data

lechnical Data		vv
Certification	MID B&D Approved	
Operating Humidity	≤ 75%	
Storage Humidity	≤ 95%	
Operating Temperature	-20°C - +50°C	
Storage Temperature	-30°C - +70°C	
International Standard	IEC 62053-21	
Accuracy Class	1	
Mounting	DIN rail (DIN 43880)	
Sealing	IP51 Indoor	
Nominal Voltage Input	(Ph+N) 230V AC	
Max Continuous Voltage	120% of nominal	
AC Voltage Withstand	4KV for 1 minute	
Impulse Voltage Withstand	6KV-1.2µS	
Reference Input current	0.5A	
Base Input Current (Ib)	10A	
Maximum Input Current (Imax)	100A AC	
Max Continuous Current	120% of nominal	
Operational Current Range	0.4% lb-Imax	
Over current withstand	20Imax for 0.01s	
Frequency	50Hz (±10%)	
Power Consumption	≤ 2W/10VA/phase	
Pulsed Output	1000imp/kWh	

Wiring Diagram

